

Town of Sahuarita

**AMENDMENTS TO THE
INTERNATIONAL PLUMBING CODE
2006 EDITION**

The following provisions of the International Plumbing Code, 2006 Edition, as published by the International Code Council, Inc. are hereby revised as follows:

Section 101.1 Title. Revise as follows:
Insert "The Town of Sahuarita" as the jurisdiction.

Section 106.6.2 Fee schedule. Revise as follows:
Insert "Sahuarita Town Code, Section 3.10.050." where indicated.

Section 106.6.3 Fee refunds. Revise as follows:
(2.) Change "[Specify percentage]", to read: "80".
(3.) Change "[Specify percentage]", to read: "80".

Section 108.4 Violation penalties. Revise as follows:
Change "[SPECIFY OFFENSE], punishable by a fine of not more than [AMOUNT] dollars or by imprisonment not exceeding [NUMBER OF DAYS], or both such fine and imprisonment." to read: "Class I Misdemeanor per Sahuarita Town Code Section 15.05.060."

Section 108.5 Stop work orders. Revise as follows:
In the last sentence change "shall be liable to a fine of not less than [AMOUNT] dollars or more than [AMOUNT] dollars." to read: "shall be liable to a fine per the town code."

Section 201.4 Terms not defined. Revise as follows:
After the first sentence add:
"Webster's Third New International Dictionary of the English Language, unabridged, shall be considered as providing ordinarily accepted meanings."

Section 312.5 Water-supply system test. Revise as follows:
Change "for piping systems other than plastic, by an air test of not less than 50 psi (344kPa). The water utilized for tests shall be obtained from a potable source of supply." To read, "for piping systems other than plastic, by an air test of not less than 50 psi (344kPa). This pressure shall be held for at least 15 minutes. The water utilized for tests shall be obtained from a potable source of supply."

Table 608.1 Application of Backflow Preventers.
Revise the device "Backflow preventer for carbonated beverage machines" as follows:
Change "low hazard" to "high hazard".
Change "backpressure or backsiphonage sizes 1/4"- 3/8" to "backpressure or backsiphonage sizes 3/8" -1".
Change "ASSE 1022, CSA B64.3.1" to "ASSE 1013 CSA 64.4".

Section 715.1 Sewage backflow.
Delete this section and replace with the following:
"Where the finish floor elevation is less than 12 inches above the elevation of the next upstream manhole cover in the public sewer, a backwater valve shall be installed in the

building drain or branch of the building drain serving that floor. Fixtures located where the finish floor elevation is 12 inches or more above the elevation of the next upstream manhole cover in the public sewer shall not discharge through the backwater valve.”